

Church Road Farms Energy Comparison

Church Road Farms 7 month Power use

Month	Billed Usage (KWH)	Scrub/Nit Use (KWH)	Cooling KWH	Ave. Bu. stored	KWH/bushel	Billed Demand (KW)
Oct.	106,000	23,760	82,240	460,000	0.18	212
Nov.	60,200	17,760	42,440	460,000	0.09	136
Dec.	34,600	17,760	16,840	460,000	0.04	74
Jan.	29,600	17,760	11,840	410,000	0.03	66
Feb.	32,000	17,760	14,240	410,000	0.03	74
March	39,000	17,760	21,240	390,000	0.05	74
April	34,000	17,760	16,240	360,000	0.05	70
7 month Totals	335,400	130,320	205,080	421,429	0.47	706

Standard control system 7 month power use documented in the same state as Church Road Farms

Month	Billed Usage (KWH)	Scrub/Nit Use (KWH)	Cooling KWH	Ave. Bu. stored	KWH/bushel	Billed Demand (KW)
Oct.	221,840	9,979	211,861	528,000	0.40	475
Nov.	295,600	7,459	288,141	498,000	0.58	551
Dec.	209,680	7,459	202,221	468,000	0.43	455
Jan.	182,080	7,459	174,621	438,000	0.40	363
Feb.	172,480	7,459	165,021	408,000	0.40	314
March	190,880	7,459	183,421	378,000	0.49	334
April	204,880	7,459	197,421	348,000	0.57	373
7 month Totals	1,477,440	54,734	1,422,706	438,000	3.27	2865